



Lassen County Environmental Health Division
 1445 Paul Bunyan Road, Suite B, Susanville, CA 96130
 TELEPHONE: (530) 251-8528 FAX: (530) 251-2668

SWIMMING POOL INSPECTION REPORT

DBA/NAME <i>Sunestang Plus Hotel by Best Western</i>						DATE <i>6/28/19</i>		
ADDRESS <i>2785 Main Street</i>				CITY <i>Susanville</i>		RECHECK DATE		
OWNER/OPERATOR <i>MALHI</i>				SERVICE		SPA TEMPERATURE °F		
POOL TYPE / PR# <i>Pool</i>	DISINFECTANT RESIDUAL <i>1.6</i> ppm	COMBINED CHLORINE RESIDUAL <i>0</i> ppm	pH <i>7.2</i>	CYANURIC ACID <i>0</i> ppm	FLOW RATE <i>75</i> gpm	INFLUENT GAUGE psi	EFFLUENT GAUGE psi	VACUUM GAUGE psi
POOL TYPE / PR #	DISINFECTANT RESIDUAL ppm	COMBINED CHLORINE RESIDUAL ppm	pH	CYANURIC ACID ppm	FLOW RATE gpm	INFLUENT GAUGE psi	EFFLUENT GAUGE psi	VACUUM GAUGE psi
POOL TYPE / PR #	DISINFECTANT RESIDUAL ppm	COMBINED CHLORINE RESIDUAL ppm	pH	CYANURIC ACID ppm	FLOW RATE gpm	INFLUENT GAUGE psi	EFFLUENT GAUGE psi	VACUUM GAUGE psi

The checked items represent violations and must be corrected as follows:

WATER CHEMISTRY *Keep Free Cl @ public pools at least 2.0ppm*

- Maintain a free chlorine residual between 1.0 ppm and 10.0 ppm, or 2.0 and 10.0 ppm if cyanuric acid is used, in swimming pools.
- Maintain a free chlorine residual between 3.0 and 10.0 ppm in spas, wading pools and spray grounds at all times.
- Maintain the level of combined chlorine between 0.4 ppm at all times.
- Maintain a pH between 7.2 and 7.8.
- Maintain the level of cyanuric acid below 100 ppm.

EQUIPMENT

- Backwash the filter(s).
- Provide, repair, or replace the vacuum gauge and/or influent/effluent pressure gauge(s).
- Provide, repair, or replace the flowmeter.
- Maintain disinfectant to the automatic feeder.
- Operate the recirculation system, including the disinfectant feeder, at all times the facility is open for use or longer as necessary to maintain the water clean and clear.

RESTROOMS

- Showers and lavatories shall be provided with hot (max. 110 degrees Fahrenheit) and cold running water.
- Provide soap in permanently installed soap dispensers, sanitary towels or hot air blowers, and toilet tissues at toilet facilities.

MAINTENANCE AND SUPERVISION

- Provide / maintain a self-closing gate / door to pool area with self-latching hardware at least 42 inches above finished grade.
- Maintain skimmer in good working order; weir assembly, strainer basket and diverter valve assembly are required.
- Limit spa pool water temperature to a maximum of 104 degrees Fahrenheit.
- Replace broken / missing / unreadable depth marker tiles and / or pool tiles.
- Secure / replace drain cover with an approved type which can only be removed with tools. Main drain must be clearly visible at all times.
- Provide / repair / replace the safety vacuum release system (SVRS).
- Secure / repair / replace loose stair handrail(s) / ladder / ladder step treads / grab rails.
- Maintain a daily log of the pool operation, disinfectant residual, combined chlorine, pH and maintenance procedures.
- Provide an approved DPD test kit.
- Provide keys to this department to gates / doors / equipment room(s) / and / or restroom facilities for inspection.

SAFETY EQUIPMENT AND SIGNS – SEE REVERSE FOR SAFETY EQUIPMENT AND SIGN REQUIREMENTS

All safety equipment must be readily accessible to pool users. All required signs must be clearly visible from the pool deck.

- SAFETY EQUIPMENT: Rescue Pole Life Ring *Add more length to rope of life ring*
- SIGNS: Artificial Respiration and CPR Emergency Phone Numbers Occupant Capacity P/S No Lifeguard on duty
- Spa Caution Emergency Shut-Off Switch Keep Closed No Diving Allowed
- Emergency Exit Diarrhea Other *Add location to signs*

Pursuant to California Code of regulations, Section 65545, THIS POOL/SPA IS OFFICIALLY CLOSED. This shall not be placed in operation until all violations have been corrected and upon specific written approval by this Division. Call to schedule a reinspection. DO NOT REMOVE THE CLOSED SIGN.

Environmental Health Specialist: <i>[Signature]</i>	Phone: <i>530-251-8528</i>	Page <i>1</i> of <i>1</i>	Received by: <i>[Signature]</i>
---	----------------------------	---------------------------	---------------------------------

DISTRIBUTION: White – Office Canary – Owner's Copy

Approved to open